



**POLLUTION CONTROL BOARD, ASSAM**  
**BAMUNIMAIDAM, GUWAHATI-781021**

**NOTIFICATION**

No. WB/T-333/2022-2023/41

Dated Guwahati the, 05<sup>th</sup> November, 2022

**Sub : Exemption of DG sets upto 1 MVA capacity from the purview of Consent Management of the Board-reg.**

In pursuance of the letter issued by the Central Pollution Control Board vide letter No. B-29012/ESS(CPA)/2015-16/8581 dated 07-03-2016 on revised categorization of the industries, the Board has decided to **exempt the standalone Diesel Generator (DG) sets of capacity up to 1 MVA** from the purview of the **Consent Management** with immediate effect subjected to the condition that the DG Sets shall be operated with proper acoustic enclosure and chimney of adequate height as per Notification under Environment (Protection) Act, 1986 vide GSR 1063(E) dated 26<sup>th</sup> December, 1998.

The Bulk Users of DG Sets like the Telecom Companies shall comply with the Hazardous and Other Wastes (Management and Transboundary Movement) Rules, 2016 and subsequently ensure that hazardous and other waste generated by them including Spent Oil and Used Batteries shall be given to authorized actual users, waste collector or operator of disposal facility in accordance with the Central Pollution Control Board Guidelines. Annual Reports and Manifest in prescribed format shall be submitted to the Board as per the governing Rules.

**(Shantanu Kr. Dutta)**  
**Member Secretary**

Memo no. WB/T-333/2022-2023/41-A

Dated Guwahati the, 05<sup>th</sup> November, 2022

Copy to:

1. PS to the Addl. Chief Secretary to the Govt. of Assam, Env. & Forest Department, Dispur-06 for kind appraisal of the Addl. Chief Secretary.
2. P.A. to Chairman, PCBA for kind appraisal of Hon'ble Chairman.
3. All Regional Heads, RO/RLO, PCBA, for information and necessary action.
4. Notice Board, Head Office/Social Media Handles/Website ([www.pcbassam.org](http://www.pcbassam.org)), PCBA.

**(Shantanu Kr. Dutta)**  
**Member Secretary**